



# EVPÜ<sup>®</sup>

NOTIFIED BODY No. 1293

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0530

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### 10 way monitor module MMX-10ME

*For specifications see Annex*

produced for

**Notifier Italia S.r.l.**

**Via Grandi, 22, 20097 San Donato Milanese (Mi), Italy**

and produced in the manufacturing plant

**IT 00942050287**


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standards

**EN 54-18:2005+AC:2007**

under system 1 are applied and that

**the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on June 08, 2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Nová Dubnica, June 08, 2016

Marek H u d á k  
Director NB



Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.

051797

## Annex to Certificate No. 1293 - CPR - 0530 from June 08, 2016

### General information

The MMX-10ME is a multi-way module card suitable for NOTIFIER analogue addressable systems and is equivalent to 10 x MMX-1 monitor modules. The MMX-10ME is 233 x 70 mm with 4 fixing holes to mount the card in a suitable box (not supplied). Each input of the MMX-10M module is suitable connection of N.O. contacts and can be configured for 2 wire or 4 wire ring connection (see below). 2 wire configuration requires the use of an End Of Line resistor (47 K - 5 % - ¼ W) supplied.

The MMX-10ME is provided with:

- 4 way DIP switch for address selection;
- 10 way DIP switch to disable single modules;
- 10 x LED's, one for each module;
- 1 x Connector to which 10 LED's can be wired (one for each module).

### Technical specifications:

External power supply:	15 + 32 Vdc (addressable loop)
Stand-by current @ 24 V:	3 mA (Not Polled)
Stand-by current @ 24 V:	4 mA (Polling, LED blink, every 5 seconds)
LED current:	5 mA (Max., each LED)
Operating temperature:	-10 + +55°C
Relative humidity:	10 + 93% (Non-condensing)

### Products parameters:

Essential characteristics	Test specification	harmonised technical specifications	Performance
Response delay (response time)	cl. 5.2	EN 54-18:2005+AC:2007	Pass
Performance under fire conditions	cl. 5.1.4	EN 54-18:2005+AC:2007	Pass
Operational reliability	cl. 5.1.4	EN 54-18:2005+AC:2007	Pass
Durability of operational reliability and response delay: temperature resistance	cl. 5.3, 5.4	EN 54-18:2005+AC:2007	Pass
Durability of operational reliability: humidity resistance	cl. 5.5, 5.6	EN 54-18:2005+AC:2007	Pass
Durability of operational reliability: vibration resistance	cl. 5.8 to 5.11	EN 54-18:2005+AC:2007	Pass
Durability of operational reliability: corrosion resistance	cl. 5.7	EN 54-18:2005+AC:2007	Pass
Durability of operational reliability: electrical stability	cl. 5.2, 5.12	EN 54-18:2005+AC:2007	Pass

Nová Dubnica, June 08, 2016



Marek Hudák  
Director NB



# EVPÜ<sup>®</sup>

NOTIFIED BODY No. 1293

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0530

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**10 way monitor module MMX-10ME**

*For specifications see Annex*

produced for

**Notifier Italia S.r.l.**

**Via Grandi, 22, 20097 San Donato Milanese (Mi), Italy**

and produced in the manufacturing plant

**IT 00942050287**


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standards

**EN 54-18:2005+AC:2007**

under system 1 are applied and that

**the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on June 08, 2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Nová Dubnica, June 08, 2016

Marek H u d á k  
Director NB



Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.

051797